

## **Leavenworth Admin Building Renovation and Cortège Parking**

893CM 3019

July 31, 2015

### Addendum Items

1. Drawing X1.11:
  - a. Spelling correction: Temporary Facilities General Notes, paragraph 3 a - "stande" should be "standard"
2. Drawing X1.11: Construction sequencing general notes, modify note 1 to add: "and erosion control" after "all related signage".
3. Drawing B1.0: Add the following to the legend:
  - a. ue = underground electric, TC = top of curb, BC = bottom of curb.
4. Drawing L1.0: Add the following to note 6: "Construction staging fence to be chain link, 6 ft. min. height. Provide gates as required for access with necessary hardware, including hasps and padlocks. Fasten fence fabric to terminal posts with tension bands and to line posts and top and bottom rails with tie wires spaced at maximum 15 inches). Bottom of fence shall extent to 1" above grade. Remove construction fence and gates at completion of the project as directed by the COTR."
5. Drawing L2.0: Add the following note: "Provide minimum 30" deep concrete frost slab for first three feet of sidewalk at building entrance."
6. Drawing L2.1:
  - a. Detail 8, plan view – ignore abandoned leader line with no text.
  - b. Add note: "Concrete flatwork to contain synthetic fiber – see spec section 32 05 23, paragraph 3.4."
7. Drawing A2.03: Add note as follows: "Infill patch to match adjacent wall, feather new siding into old siding, infill area to corner of building. Typical for all infill areas. Prime and paint entire wall."
8. Drawing A3.01: Add note as follows: "Field verify – patch window opening size. Blend siding into existing. Prime and paint entire field from both vertical trim pieces and from stone to horizontal trim at 109' – 41/2". Paint to match existing. Submit color samples for approval. "
9. Drawing A6.01, Detail 5: Add the following note: "provide 4 inches of extruded polystyrene insulation and vapor barrier under new floor slab".
10. Drawing A8.01:
  - a. Details 5-8, Add two additional rows of ceramic tile.
  - b. Toilet Accessories Legend. Delete changing station for infants.
11. Drawing A9.02: Add note as follows: "Interior signage – refer to VA Signage Design Guide, December 2012 Edition, Section 12-4-41 through 12-4-46."
12. Drawing P0.1: General Plumbing Notes, note 1 should read as follows: "Install all plumbing in accordance with the Kansas Plumbing Code and regulations of all authorities having jurisdiction."
13. Drawing P1.1: Add note: "Restore concrete floor slab cut out to match thickness and finish of existing slab. See spec section 03 30 53."
14. Drawing SS1.1: Replace existing drawing with revised 7/31/15 Addendum drawing.
15. Spec Section 01 45 29; Section 3.18 – modify quantity of tests as follows: Earthwork, Field Density Test - 6, Aggregate Base Course Field Density Test – 6, Asphalt Concrete Field Density Test – 4; Concrete, Cylinders – 6, Compressive Strength 6, Slump Test – 4, Air Content – 4.

16. Sec section 08 31 13, Access Door Frames: This is a new spec section added as part of the 7/31/15 Addendum.
17. Spec Section 23 05 93: Delete paragraph 1.1.B.5.
18. Spec section 23 07 11:
- a. Paragraph 2.1B should read as follows: "ASTM C553 (Blanket, Flexible) Type I, Class B-5, Density 32 kg/m<sup>3</sup> (2 pcf), k = 0.04 (0.27), for use at temperatures up to 20 degrees C (400 degrees F) with foil scrim (FSK) facing."
  - b. Paragraph 3.1G should read as follows: "Elbows, flanges and other fittings shall be insulated with the same material as is used on the pipe straights. The elbow/fitting insulation shall be field-fabricated, mitered or factory prefabricated to the necessary size and shape to fit on the elbow/fitting. Use of polyurethane spray foam to fill a PVC elbow jacket is prohibited on cold applications."
19. Spec Section 32 12 16:
- a. Paragraph 1.5.B.1 – "state highway department" is Kansas Department of Transportation (KDOT).
  - b. Paragraph 2.4 – revise first sentence to read: "Comply with provisions of KDOT HMA-Commercial Grade Class A."
20. Spec Section 07 46 23:
- a. Paragraph 1.1 modify to read as follows: "This section specifies fire retardant treated wood cedar siding".
  - b. Paragraph 3 C. Add the following sentence as the last sentence: "New siding to be feathered into the existing. Prime and paint entire wall.
21. Spec section 08 71 00: Paragraph 3.5 Hardware Sets, add Pull 658A to Hardware Group 8.
22. Spec section 08 80 00: Paragraph 3.13F Add No.3 as follows: "Tint on new exterior glass to match tint on existing exterior glass. Submit sample for approval."
23. Spec Section 09 30 13: Paragraph 2.1E – Delete reference to Section 09 06 00. Add the following:

CT1 Floor Tile	Daltile	6.5 x 6.5 Tile and Cove Base(SC-36E9t, S-36E9T) P501 Gravel
Wall Tile Field	Daltile	Rittenhouse X735 Matte Almond 3x6 Rectangle Field
Wall Tile Bullnose	Daltile	Rittenhouse X735 Matte Almond 3x6 Rectangle Bullnose

24. Spec section 09 68 00:
- a. Delete reference to section 09 06 00.
  - b. Paragraph 2.2C should read as follows: "Pattern Name – Historical Revival Loop, Pattern Number 8LH240000T, Color Name – Layout, Color Number 880239."
25. Spec section 09 91 00:
- a. Delete all references to section 09 06 00.

- b. Paragraph 3.8A. Sentence should read as follows: "Paint color PT-1 to be Sherwin Williams SW6126 Navajo White – Eggshell type finish."
  - c. Exterior
- 26. Spec Section 10 28 00: Delete paragraph 3.3 Schedule of Accessories. Required toilet accessories are listed on drawing A8.01.

END of ADDENDUM